LISTING SERVICE

LISTING No.   7272-0801:193   Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Radionics, Div. of Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY, 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060

DESIGN: Models D7040, D7040TH and D7040THL addressable photoelectric type smoke
detectors. Models D7040TH and D7040THL employ an integral 135^0 fixed temperature
heat sensor. This heat sensor is intended for use only as a supplemental device to assist
the smoke detector. Refer to listee's data sheet for additional detailed product
description and operational considerations.

RATING: Supplied by Model DS7400 series fire alarm control unit through multiplex bus

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use only with Detection Systems' separately
listed Model DS7400 Series fire alarm control unit (CSFM Listing No. 7165-1062:113).
Units must be connected to the multiplex bus of the fire alarm control unit for both
power and signaling.

XLF: 7272-1062:120

*Rev. 05-31-2002

Date Issued: **MAY 31, 2002**   *Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, *Senior Deputy*
Program Manager